

# Instruction Letter

---

Subject:	Form 6 Recloser Control ProView 4.0.1 Software Upgrade Wizard Information Supplement	Number:	280-478
To:	HQa, Sales Force (S), Product Groups (PG)	Date:	March 3, 2008
From:	Richard Hein, Global Product Director - Intelligent Electronic Devices	File:	280-70
Attachment:	<a href="#">S280-70-20 Form 6 Recloser Control ProView 4.0.1 Application Software Upgrade Wizard Informational Supplement</a>	Cancel:	None

---

ProView 4.0.1 (P/N: 6A00182610 Rev. 03) Application Software  
Available for the Form 6 Recloser Control

## Form 6 Control Upgrade Wizard Version Clarification

ProView 4.0.1 (P/N: 6A00182610 Rev. 03) application software for the Form 6 recloser control was released in November 2007 to resolve structure differences that occurred with one of the three modes of the upgrade wizard included with ProView 4.0.1 (P/N: 6A00182610 Rev. 02) application software released in October 2006.

The ProView 4.0.1 Rev. 03 application software CD provides the latest installation files for the program and accompanying ProView 4.0-4.0.1 Software Upgrade Wizard for the standard release of the Form 6 recloser control. There are no other updates when compared to the ProView 4.0.1 Rev. 02 software. The ProView software remains unchanged.

## Date Modification Issue

When the "Convert a Form 6 V4.0 scheme file into a Form 6 V4.0.1 scheme file" Upgrade Wizard option is used with the ProView 4.0.1 Rev. 02 software for the Form 6 control, some files in the ProView 4.0 software installation are modified on the local computer. If this same personal computer (PC) is used to establish communications with a Form 6 control that is using ProView 4.0 software, the comparison dialog will indicate a structure difference (even if the scheme structures are the same). This structure difference can lead to varying levels of inconvenience for your customers.

There are three Upgrade Wizard options. This date modification only occurs with the option described above.

## Next Steps

*Service Information S280-70-20* provides supplemental information and instructions regarding the Upgrade Wizard included on the standard Form 6 Recloser Control ProView 4.0.1 application software CD. These instructions are intended to be used in conjunction with the Upgrade Wizard instructions included on the ProView 4.0.1 software CD and the programming instructions for the Form 6 Recloser Control.

- Familiarize yourself with the *S280-70-20 Form 6 Recloser Control ProView 4.0.1 Application Software Upgrade Wizard Informational Supplement*. Provide this tool to your affected customers as you approach them with reassurance that Cooper Power Systems can help to resolve issues that may have occurred as a result of use of the "Convert a Form 6 V4.0 scheme file into a Form 6 V4.0.1 scheme file" Upgrade Wizard option available with the ProView 4.0.1 Rev. 02 software for the Form 6 control.
- Cooper Power Systems recommends that you provide your customers with the Form 6 control ProView 4.0.1 (P/N: 6A00182610 Rev. 03) application software CD already available at our literature fulfillment center.

Contact the Switchgear Support Group (SSG) at (800) 497-5953 or by email at [SSG@CooperIndustries.com](mailto:SSG@CooperIndustries.com) if you have any further questions or need additional assistance.